



UST Field Notice of Non-compliance

No. **1810**

The Environmental Protection Agency (EPA) is responsible for the enforcement of underground storage tank (UST) laws that protect human health and the environment. Pursuant to federal regulation at 40 CFR Part 280, during an inspection on

10/13/09
(Date)

the following items of UST non-compliance were observed at your facility:

1	Description: 49CFR 280.31(b) Failure to ensure proper operation of cathodic protection system.	Correction Required: send to EPA copy of Nov 2007 C.P. Tests.	Deadline: 11/13/09
2	Description:	Correction Required:	Deadline:
3	Description:	Correction Required:	Deadline:
4	Description:	Correction Required:	Deadline:

WARNING

The EPA wishes to work cooperatively with you as the owner and/or operator of this facility to resolve the violation(s) listed above at this time. Therefore, no penalty will currently be assessed. However, if you fail to complete the above noted compliance task(s) before the listed deadline(s), you will become subject to citation and/or formal enforcement action. Such enforcement actions mandate compliance and carry monetary penalties as high as \$11,000 for every day of continued violation on each underground tank.

Notify your EPA contact person (listed below) immediately if you are unable to perform the required actions within the specified dates.

EPA Inspector	
Name:	Philip Penninger
Office Address:	1200 Sixth Ave Ste 5000 OCE-1641 Seattle, WA 98101
Phone:	206-553-4012 / 7176
Signature:	[Signature]

Facility Information	
Name of Facility:	Smith's Coroco
Address:	102 E. Toppenish Ave Toppenish, WA 98948
Contact:	Susan Smith
Signature:	Susan K Smith (Signature acknowledges receipt only)